

LOL-HECO-IR-35

Ref: "Utilizing renewable energy such as wind and PV is not a feasible option" (Exhibit 6, page 8)

Question(s):

Has HECO or its affiliates conducted any type of study as to the PV MW potential of rooftops in the Pukele Service Area?

HECO Response:

No study has been conducted as to the PV MW potential of rooftops in the Pukele Service Area.

As noted in Exhibit 6, page 8 of the Application, PV (without an energy storage system) is an intermittent generation source and therefore cannot be relied upon to address the Koolau/Pukele Overload situation. Therefore, there would be no benefit to study the PV MW potential of rooftops in the Pukele Service Area as it relates to this project.